



SIRIM QAS International Sdn. Bhd. (410334-X)
No.1, Persiaran Dato' Menteri, P.O.BOX 7035, Section 2,
40700 Shah Alam, Selangor Darul Ehsan, Malaysia
Tel: 03-55445892
Fax: 03-55445855
www.sirim-qas.com.my

TEST REPORT

REPORT NO : 2018CB1115	PAGE : 1 OF 2
This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the Managing Director, SIRIM QAS International Sdn. Bhd. Please refer the last page for Conditions Relating to the Use of Test Report.	

THIS TEST REPORT IS ISSUED IN SECURED PDF SOFTCOPY

Applicant : MAXIM MATERIALITY SDN. BHD.
No. 15, Jalan SBC 7, Taman Sri Batu Caves,
68100 Batu Caves, Selangor Darul Ehsan.

Manufacturer :

Product : High Security Welded Fence (Hot Dipped Galvanised Finishing)

Reference Standard / Method of Test : BS EN 10223-7 : 2012 Steel wire and wire products for fencing and netting. Steel wire welded panels for fencing
Clause 7.1 – Tensile strength
Clause 7.3 – Mesh dimensions and tolerance
Clause 7.4.1 – Zinc and zinc alloy coatings

Description of sample / Description of Test Specimen : Two (2) samples of High Security Rolled Top Welded Fence (Hot Dipped Galvanised Finishing) were received for testing.
Brand : Envigal
Size : Spacing 25 mm (vertical) x 75 mm (horizontal) or equivalent to 4 mm (dia)

Date Received of Complete Application : 23 March 2018

Job No. : J20181430403

Description of Test Results / Overall Test Result : This test report covers only test clauses as requested by Applicant to SIRIM QAS International Sdn. Bhd. The test results for the submitted test samples as described in this test report complied with the requirements of the above reference standard at the respective clauses tested.

Issued Date : 30 July 2018

Approved Signatories;

(MOHAMAD RAZIQI BIN SHA'ABAN)
Testing Executive



(RAJAHANOR SIHA BINTI RAJA ABDUL HANAN)
Head
Civil & Construction Section
Testing Services Department

This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the Managing Director, SIRIM QAS International Sdn. Bhd. Please refer the last page for Conditions Relating to the Use of Test Report.

STANDARD REFERENCE : BS EN 10223-7 : 2012

SAMPLE REFERENCE : HIGH SECURITY WELDED FENCE (HOT DIPPED GALVANISED FINISHING)

CLAUSE	REQUIREMENT	RESULTS	REMARKS
7.1 TENSILE STRENGTH			
Diameter (mm)	-	3.99	-
Maximum load (kN)	-	6.65	-
Tensile strength (MPa)	350 to 950	585	Pass
7.3 MESH DIMENSIONS AND TOLERANCE			
Longitudinal (mm)	25 ± 3.0	25.20	Pass
Transverse (mm)	75 ± 3.0	75.12	Pass
7.4.1 ZINC AND ZINC ALLOY COATINGS			
Class A (g/m ²)	270 min.	715	Pass

(The remainder of this page is intentionally left blank)

